

Water Department Activities for March 2011

- 2 Bacteria samples were taken and sent to lab
- New relays were installed on well pumps and tower levels were monitored while repairs were made
- Average daily usage for the month: 218,194 gallons (10- 219,581; 09 - 220,581; 08 - 268,581; 07 - 266,032; 06 - 270,355)