

Water Department Activities for June 2011

- 2 Bacteria Samples were taken and sent to lab
- Met with Trustee Seymour various times to discuss water issues
- Water Leak on Cherry Street in the area of Stewart's was repaired
- Checked out a reported leaky meter at 10 Phillips Street – meter not leaking (condensation)
- Average daily usage for the month: 252,300 gallons (10 – 243,567; 09 – 233,867; 08 – 294,533; 07 – 288,533; 06 – 285,633)