

Water Department Activities for February 2009

- ❖ 2 Bacteria Samples were taken and sent to lab**
- ❖ Inorganic, SOC & Radiological samples were taken and sent to lab as required by DCDOH**
- ❖ Turned water off and back on at 90 Cambridge for repairs as requested**
- ❖ Found leak at Stewart's and fixed temporarily**
- ❖ Leaking water meter was replaced at Agway**
- ❖ Average daily usage for February: 232,214 gallons
(08 – 263,793; 07 – 265,893; 06 – 266,750; 05 – 256,536)**